

CITY OF WALLIS
SAFETY INSPECTION CHECKLIST FOR
MOBILE HOMES

1. Address (number only) must be placed on the mobile home (4" inches tall)
2. All outlets must have covers on them
3. All light fixtures must have cover on them.
4. Smoke detectors need to be placed in each bedroom and in any hall adjacent to the bedrooms and living room.
5. Skirting, all mobile homes are to be skirted with non-flammable material
6. Steps must be installed properly with handrails (please see attached examples)
7. Fire extinguisher
8. Anti-tip device on stove
9. No open spaces in breaker box